

SECTION 23 05 00**COMMON WORK RESULTS FOR HVAC****PART 1 - GENERAL****1.1 RELATED DOCUMENTS**

- A. The Conditions of the Contract including the General Conditions, Supplementary Conditions, and Division One, shall apply to work of this Division, whether attached or not.
- B. The requirements specified in this Section shall be applicable to work specified in other Sections within this Division.

1.2 SCOPE OF WORK

- A. All Division 23 sections of these specifications shall include all labor and material to complete the entire mechanical systems as specified and shown on the Drawings.
- B. All work shown and specified shall be completely installed and connected by mechanics properly qualified to perform the work required. All work shall be left in a satisfactory operating condition as determined by the Owner and Owner's Representative.
- C. Provide all services and perform all operations required in connection with, or properly incidental to, the construction of complete and fully operating systems with all accessories as herein specified and shown on the Drawings.
- D. Refer to "Conditions of Work" in Division 1.

1.3 GENERAL

- A. The accompanying Drawings show diagrammatically the sizes and location of the various equipment items and the sizes of the major interconnecting piping and ductwork, without showing exact details as to elevations, offsets, control lines, and other installation details. The Contractor shall carefully lay out his work to conform to the site conditions, to avoid obstructions and provide proper grading of lines. Exact locations of outlets, apparatus, and connections thereto shall be determined by reference to the Drawings, reviewed Shop Drawings, including equipment drawings, and rough-in drawings, by measurements at the building, and in cooperation with work specified in other sections of these specifications. Minor relocations necessitated by the conditions at the site or directed by the Engineer shall be made without any additional cost to the Owner.

- B. These specifications and the accompanying Drawings are intended to describe and illustrate systems which will not interfere with the structures, which will fit into available spaces, and which will insure complete and satisfactorily operating installations. Contractor shall coordinate the proper fitting of all material and apparatus into the building and shall prepare larger scale installation drawings for all critical areas, areas with limited working clearances, and areas of significant congestion requiring a higher level of coordination illustrating the installation of work specified in Division 23 in relation to all other portions of work specified in other Sections of these Specifications. Interferences with other portions of work, or the building structure, shall be corrected before any work proceeds. Should changes become necessary on account of the failure of the Contractor to comply with these stipulations, Contractor shall make all necessary changes at no expense to the Owner.
- C. All work shall be run parallel or perpendicular to the lines of the building unless otherwise noted on the Drawings.
- D. It is the intent of the Contract Documents to provide an installation complete and operational in every respect. In the event that additional details or special construction may be required for work indicated or specified in this section, or work specified in other sections, it shall be the responsibility of the Contractor to provide same as well as to provide material and equipment usually furnished with such systems and required to complete the installation.
- E. Contractor sets forth that all personnel have the necessary technical training and ability; and that all work specified in this Division will be installed to the best standard of each trade, and will be complete and in good working order. If any of the requirements of the Drawings and specifications are impossible to perform, or if the installation when made in accordance with such requirements will not perform satisfactorily, report same to the Engineer promptly after discovery of the discrepancy.
- F. No extra compensation will be allowed for extra work or changes caused by failure to comply with the above requirements.

1.4 EXAMINATION OF THE SITE

- A. Contractor shall visit the site, verify all items indicated on the Drawings or specified, and familiarize himself with the work conditions, hazards, grades, actual formations, soil conditions, points of connection, utility locations, and local requirements.
- B. Contractor shall take these conditions into consideration, and the lack of specific information on the Drawings shall not relieve the Contractor of any responsibility.

- C. All site visits shall be coordinated and scheduled with the Owner.

1.5 CUTTING AND PATCHING

- A. Excessive cutting of the building structure, walls, floors, ceilings, roof, etc., will not be permitted. No structural member shall be notched or cut unless specifically shown on the Drawings, or unless such cutting is authorized by the Engineer.
- B. Provide for all holes or openings of proper size and shape as may be necessary for the proper installation of work specified in Division 23, consulting with the Engineer regarding proper locations and sizes.
- C. Where deemed necessary, and after consulting with the Engineer, perform all cutting and patching required for the installation of piping, ductwork, etc. This shall include the cutting of concrete floors, concrete and tile floors, walls, ceilings, roofs, etc. It shall also include patching them as required to restore work to match existing finishes, following installation, testing, backfilling, insulation, etc.
- D. Holes through concrete shall be drilled with "Mole", "Core-It", or other diamond point hole saw.
- E. Refer to Section 01 04 50, Cutting and Patching.

1.6 CODE REQUIREMENTS

- A. Contractor is required to comply with the requirements of all National, State, and local codes and utility companies having jurisdiction. In no case does this relieve the Contractor of the responsibility of complying with the requirements of these specifications and Drawings where specified conditions are of higher quality than the requirements of the above specified offices. Where requirements of the specifications and Drawings are below the requirements of the above offices having jurisdiction, the Contractor shall make installations in compliance with the requirements of the above offices and shall notify the Engineer promptly.
- B. Contractor shall comply with the requirements and standards set forth by, but not limited to, the following:
 - 1. (NFPA) National Fire Protection Association.
 - 2. (OSHA) Occupational Safety and Health Administration.
 - 3. (NEC) National Electric Code.
 - 4. (IECC) International Energy Conservation Code.
 - 5. Local Plumbing Code.
 - 6. Local Building Code.
 - 7. Local Mechanical Code.
 - 8. Local Fire Code.
 - 9. Local Energy Code.

- C. Contractor shall obtain all permits, inspections, and approvals as required by all authorities having jurisdiction. Fees and costs incidental to these permits, inspections, and approvals must be assumed and paid by the Contractor.

1.7 RECORD DRAWINGS

- A. Contractor shall, during the execution of work, maintain a complete set of "Record Drawings" upon which all locations of equipment, ductwork, piping, and all deviations and changes in the work shall be neatly recorded for use in producing "As Builts" at Project Close- Out. This shall include the incorporation of all Supplemental Drawings issued during the Construction Period.
- B. All "Record Drawings" shall be reviewed monthly during the Construction Period, along with the monthly Pay Application Request.
- C. Refer to Section 01 07 00, Contract Close-Out.

1.8 RECORDS AND INSTRUCTIONS FOR OWNER

- A. Accumulate during the job's progress the following sets, in triplicate, in accordance with the provisions of Section 01 70 00 & 01 73 00:
 1. Warranties and guarantees and manufacturer's directions on equipment and material covered by the Contractor.
 2. Equipment and fixture brochures, wiring diagrams, and control diagrams.
 3. Copies of reviewed Shop Drawings, and material and equipment submittals. Copies of rejected submittals and Shop Drawings are not to be provided.
 4. Operating instructions for heating and cooling and other mechanical systems. Operating instructions shall include recommended maintenance and seasonal change-over procedures.
 5. Other data and drawings required during construction.
 6. Repair parts lists of all major items and equipment including name, address, and telephone number of local supplier or agent.
 7. Valve tag charts and diagrams specified elsewhere herein.
 8. "As-Built" Record Drawings shall be provided in electronic format on a USB Drive (provide two (2) copies) in a PDF or DWG format as determined by the Owner.
 9. Provide copies of all City Inspection Certificates of Approval.
 10. Provide Contractor's Certification Statement that all equipment furnished and all work performed is in compliance with all applicable codes referenced in these specifications, or those which are currently in effect.
- B. Provide not less than one (1) days of operating instructions, during the adjustment and testing period, to the Owner's operating personnel in order to familiarize them with the proper care and operation of all equipment.

- C. All of the above data should be submitted to the Engineer for approval at such time as the Contractor asks for his last payment request, just prior to his final payment request. In no case will any portion of retainage be released until these documents are submitted and accepted.
- D. Refer to related portions of Division 1 for Project Close-Out requirements, Operation and Maintenance Data, Warranties, and other related certificates.

1.9 SHOP DRAWINGS AND SUBMITTALS

- A. Contractor shall submit to the Engineer shop drawings, product submittals, and catalog data on all ductwork, equipment, and materials designated on the Drawings and specified herein. A minimum of three (3) copies of each shall be submitted or submittal shall be transmitted electronically. Additional copies will be required when indicated by the Engineer and as required for project coordination.
- B. Each submittal will be reviewed for compliance with general requirements of design and arrangement only; it is not a contract document and acknowledgement of compliance does not relieve the Contractor from responsibilities for performance of the work in compliance with all provisions and requirements of the Contract Documents. Job measurements and the coordination of all dimensions for proper fit of all parts of the work and performance of all equipment supplied to meet specification requirements are, and remain, specific responsibilities of the Contractor.
- C. Shop Drawings shall be furnished by the Contractor for the work involved after receiving approval on the make and type of material and in sufficient time so that no delay or changes will be caused. This is done in order to facilitate progress on the job, and failure on the part of the Contractor to comply shall render him liable to stand the expense of any and all delays, changes in construction, etc., occasioned by his failure to provide the necessary detailed drawings. Also, if the Contractor fails to comply with this provision, the Engineer reserves the right to go directly to the manufacturer he selects and secure any details he might deem necessary; and, should there be any charges in connection with this, they shall be borne by the Contractor.
- D. Shop Drawings submitted shall not consist of manufacturers' catalogues or tear sheets therefrom that contain no indication of the exact item offered. Rather, the submission on individual items shall designate the exact item offered and accessories as specified.
- E. Shop Drawings are not intended to cover detailed quantitative lists of heating specialties, valves, air distribution devices, fixtures, and similar items, as the Drawings and specifications illustrate those items; and it is the Contractor's responsibility to procure the proper quantities required to comply with the established requirements.

- F. Shop Drawings prepared to illustrate how equipment, piping, ducts, etc., can be fitted into available spaces will be examined under the assumption that the Contractor has verified the conditions shown. Review by the Engineer shall not relieve the Contractor of responsibility in the event the material cannot be installed as shown on those Shop Drawings.
- G. Various material submissions of such items as air devices, plumbing fixtures, drains, and other related items or accessories shall be assembled in brochures or in other suitable package form and shall not be submitted in a multiplicity of loose sheets. Cover sheets for each item submitted shall have sufficient bare space to allow for shop drawing review stamps.
- H. Contractor shall process his submitted data to insure that it conforms to the requirements of the Drawings and specifications, and there are no omissions and/or duplications.
- I. Shop Drawings and Submittals shall be accompanied by certification from the Contractor, and firm preparing such, that Shop Drawings have been checked for, and are in compliance with, the Contract Documents.
- J. All Submittals and Shop Drawings shall have been submitted for review by the Engineer and Engineer within 90 days after Contract Award Date.

1.10 PENETRATIONS THROUGH FIRE-RATED ASSEMBLIES

- A. Seal voids around ducts and pipes penetrating fire-rated assemblies and partitions using fire-stopping materials and methods.

1.11 DRAWINGS

- A. Drawings show diagrammatically the locations of the various pipes, ductwork, fixtures, and equipment, and the method of connecting and controlling them. It is not intended to show every connection in detail and all fittings required for a complete system. The systems shall include, but are not limited to, the items shown on the drawings. Exact locations of these items shall be determined by reference to the general plans and measurements at the building, and in full cooperation with work specified in other Divisions of these specifications; and, in all cases, shall be subject to the approval of the Engineer. The Engineer reserves the right to make any reasonable change in the location of any of this work without additional cost to the Owner.
- B. Should any changes be deemed necessary in items shown on the Contract Drawings, the shop drawings, descriptions, and the reason for the proposed changes shall be submitted to the Engineer for approval.

- C. Exceptions and inconsistencies in plans and specifications shall be brought to the Engineer's attention prior to bids being submitted; otherwise, the Contractor shall be responsible for the cost of any and all changes and additions that may be necessary to accommodate the installation of any particular apparatus.
- D. Lay out all work maintaining all lines, grades, and dimensions according to these Drawings with due consideration for the work of others. Verify all dimensions at the site prior to any fabrication or installation. Should any conflict develop or installation be found impractical, the Engineer shall be notified before any installation or fabrication, and the existing conditions shall be investigated and proper changes effected without any additional cost.
- E. Titles of Sections and Paragraphs in these specifications are introduced merely for convenience and are not to be construed as a correct or complete segregation or tabulation of the various units of materials and work. The Engineer does not assume any responsibility, either direct or implied, for omissions or duplications by the Contractor due to real or alleged error in the arrangement of matter in the Contract Documents.

1.12 CONNECTION OF EQUIPMENT FURNISHED BY OTHERS

- A. Equipment supplied as portions of work specified under other Divisions of these specifications shall be furnished with proper roughing-in diagrams and shall be installed as a part of Division 23.
- B. Furnish materials and labor required for the connection of this equipment.
- C. Contractor shall ascertain that all equipment so specified is included as part of this work.

1.13 COOPERATION

- A. Coordinate all work indicated in Division 23 with work specified in other Divisions to assure proper and adequate interface with other portions of the work.
- B. Maintain contact and be familiar with the progress of the general construction and the timely installation of sleeves and inserts, etc., before concrete is placed. Install the required systems in their several stages, at the proper time to expedite the work and avoid unnecessary delays in the progress of other portions of the work.
- C. Should any questions arise between work specified in Division 23 with respect to other portions of work specified in other Divisions of the Specifications, reference shall be made to the Engineer for instructions.

1.14 MATERIALS AND EQUIPMENT

- A. All materials and equipment purchased shall be new. No used or reconditioned equipment will be allowed.
- B. Substitutions: Products of same functions, performance and design will only be considered if in full accordance with the requirements of Section 01 60 00, Material and Equipment. The products of other manufacturers will be acceptable; only if, in the opinion of the Engineer, the substitute material is of a quality as good or better than the material specified, and will serve with equal efficiency, maintainability, and dependability, the purpose for which the items specified were intended.
- C. Listed Manufacturers:
 - 1. Manufacturers listed in a product or system specification are those manufacturers considered capable of manufacturing products conforming to the specification requirements, and are listed therein to establish a standard.
 - 2. The "listing" of a manufacturer does not imply "acceptance" or "approval" of any standard product of that manufacturer.
 - 3. Products offered by listed manufacturers shall be equal to, or superior in all respects to, that specified by named products; and shall meet or exceed specification requirements.
 - 4. The description of specific qualities takes precedence over the reference standards and the description of qualities and reference standards together take precedence over the named product of listed manufacturers.
- D. Product Options:
 - 1. Products specified only by Reference Standards or by Description only means that any product meeting those standards or descriptions, by any manufacturer, will be considered.
 - 2. Products specified by naming several products or manufacturers means that only the manufacturers named will be considered.
 - 3. Products specified by naming only one product and manufacturer means that no option exists unless a substitution is accepted. Submit a request for substitution for any product or manufacturer not specifically named.
 - 4. Products specified by Description, Reference Standard, and naming several products or manufacturers means that any product and manufacturer named meeting those descriptions and standards will be considered. Submit a request for substitution for any product or manufacturer not specifically named.
- E. Limitations or Substitutions:
 - 1. During Bidding Period, Instructions to Bidders, in Division 1, will govern times for submitting requests for substitutions under requirements specified in this Section.
 - 2. No later than ten (10) days prior to the bid date, Contractor shall notify the Engineer in writing of any desired substitutions of products in place of those

- specified. These requests will be considered; and, if a favorable response is determined, this will be documented in the form of an Addenda.
3. Substitutions will not be considered when indicated or implied on Shop Drawings or product data submittals without separate formal request, when requested directly by subcontractor or supplier, or when acceptance will require substantial revision of Contract Documents.
 4. Substitute products shall not be ordered or installed without written acceptance.
 5. Only one request for substitution for each product will be considered. If substitution is not accepted, Contractor shall provide specified product.
 6. Engineer will determine acceptability of any and all substitutions.
- F. It is fully the Contractor's responsibility to assemble and submit sufficient technical information to fully illustrate that the material or equipment proposed for substitution is equal or superior, as the Engineer is under no obligation to perform the service for the Contractor. The proposal shall be accompanied by manufacturer's engineering data, specification sheet, and a sample, if practical or if requested or specified. In no event shall a proposal for substitution be cause for delay of work. This shall include a detailed comparison to each product specification paragraph.
- G. Should a substitution be accepted under the above provisions, and should the substitution prove defective or otherwise unsatisfactory for the intended service, within the warranty period, the Contractor shall replace the substitution with the equipment or material specified, and on which the specifications required him to base his proposal.
- H. No substitutions will be considered contingent upon pending certification and rating agency approvals. Such certifications and ratings shall be in effect at the time of bidding.

1.15 EQUIPMENT SIZES AND REQUIREMENTS

- A. Space allocations in machinery and mechanical equipment spaces are based on equipment scheduled in each case. Should the Contractor request a substitution for equipment of another make that requires more space in any critical dimension, the Contractor shall submit, together with other submittal data on the equipment, prints of drawings indicating how the equipment may be installed, indicating room for servicing and revisions in piping or ducting and any other details necessary for the Engineer to form a judgement as to the suitability of the substitute material, as to performance, suitability for the space and other variables.
- B. Duties of certain equipment items, horsepower of driving motors and electrical characteristics are scheduled for equipment items of a particular make in each case. Should requests for a substitute material be accepted which has other requirements that would involve allied equipment or other portions of work, the Contractor shall be responsible for all modifications required at no change in contract price. As examples:

1. If an accepted A/C Unit has a brake horsepower requirement above the motor horsepower scheduled, the Contractor shall be responsible for providing a larger motor and heavier drive and any change in size of the protective device, conduit run and conductors serving that motor. The latter shall be extended through an individual branch protective device and branch circuit on through the panel, feeder, feeder protective device, etc.
 2. If accepted, heat exchangers, coils, etc., having greater pressure drops than those on which pumping heads were based, the Contractor shall be responsible for selecting proper pumps and drives and adjusting electrical service work accordingly.
- C. Structural steel members are indicated to provide supports for certain specific sizes and weights of equipment. Should a substitution request involve other equipment, the spacing of the supports shall be varied to suite the equipment. Should the weight or size of a proposed substituted item of equipment require additional supporting steel members, the Contractor shall include documentation of the additional supports in the request for substitution and install them at no change in contract price if the substitution is accepted.
- D. Various large apparatus to be installed may require that the apparatus be installed prior to the installation of portions of structural, walls, or door frames. Coordinate the installation of these items to insure that no demolition of general construction is necessary for equipment installation or that the apparatus does not have to be disassembled for installation.

1.16 STORAGE AND PROTECTION OF MATERIALS

- A. Store and protect materials and equipment as specified in Section 01 60 00, Material and Equipment.
- B. Contractor shall provide storage space for protection and storage of his materials and assume complete responsibility for all losses due to any cause whatsoever. All storage shall be within the property lines of the building site, and as directed by the Engineer. In no case, shall storage interfere with traffic conditions in any public or project thoroughfare.
- C. All work and material shall be protected at all times. Contractor shall make good any damage caused, either directly or indirectly, by his workmen. He shall be responsible for safe handling of all mechanical equipment and shall replace, without charge, all items damaged prior to acceptance by the Owner.
- D. On site storage shall not be inside the building during construction progress, but shall be in approved trailers or as specifically approved otherwise by the Engineer. Storage inside the building shall only be allowed when so allowed by the Engineer.

1.17 FOUNDATIONS

- A. Provide equipment foundations associated with the work specified in Division 23.
- B. All top corners and edges of all foundations shall be neatly chambered at a one inch (1") high 45 degree angle.
- C. Foundation bolts shall be placed in the forms when the concrete is poured. Allow one inch (1") below the equipment bases for alignment, leveling, and grouting with non-shrinking grout. Grouting shall be done after the equipment is leveled in place. After the grout has hardened, the foundation bolts shall be pulled up tight and the equipment shimmed, if necessary.
- D. After removal of the forms, the surface of the foundation shall be rubbed until smooth.
- E. Unless otherwise noted, foundations shall be four inches (4") thick elsewhere for low pressure rated air handling units and other mechanical equipment, unless specifically noted otherwise on the Drawings.
- F. Provide housekeeping pads and foundations for every item of floor mounted equipment specified in Division 23 specifications. Pads shall be a minimum of 4 inches thick extend a minimum of two inches (2") in each direction beyond the equipment size.

1.18 EXCAVATION AND BACKFILLING

- A. Contractor shall do all necessary excavating and backfilling for the installation of his work. Trenches for underground conduits shall be excavated to required depths with bell holes provided as necessary to insure uniform bearing. Care shall be taken not to excavate below depth, and any excavation below depth shall be refilled with sand or gravel firmly compacted. Where rock or hard objects are encountered, they shall be excavated to a grade six inches (6") below the lowermost part of the piping and refilled to grade as specified. After the piping has been installed and reviewed by Engineer and local building authorities, trenches shall be backfilled to grade with approved materials, well tamped or puddled compactly in place. Where streets, sidewalks, etc., are disturbed, cut, or damaged by this work, the expense of repairing same in a manner approved by Engineer shall be a part of this contract.
- B. Contractor shall bear sole responsibility for design and execution of acceptable trenching and shoring procedures, in accordance with State of Texas Regulations. On trench excavations in excess of five feet (5') in depth, Contractor shall pay a qualified engineer to prepare detailed Drawings and specifications directing Contractor in the safe execution of trenching and shoring. It is understood that trench safety systems constitute a means and method of construction for which the Engineer and Owner are

not responsible. Accordingly, such documents when prepared, shall be separately issued by Contractor's Consultant, independent of project contract Documents.

1.19 WIRING

- A. Unless otherwise noted, all wiring for motors, starters, and equipment is specified in Division 26.
- B. Wiring of temperature controls shall be performed in accordance with the requirements of Division 26 but shall be performed as outlined in other sections of these specifications.
- C. All power for control circuits required for the Temperature Control System shall be provided and installed where indicated on the Division 26 Drawings, but shall otherwise be provided as indicated in other sections of these specifications.
- D. Each supplier of equipment requiring control shall have wiring diagrams furnished with submittals. This shall be used to determine conduit layouts required to complete the electrical portions of the instrumentation and control systems.
- E. All motors furnished as a portion of work specified in Division 23 shall be wired as specified in Division 26.
- F. Except where combination starter-disconnects are specified elsewhere herein or in Division 26, all motors shall be provided with safety disconnect switches in accordance with the National Electrical Code as specified in Division 26.
- G. Furnish all necessary wiring diagrams for equipment specified in Division 23, as a part of equipment submittals, for installation under other sections of these specifications.

1.20 EQUIPMENT STANDARDS

- A. All basic materials and equipment shall be standard catalog products of a reputable manufacturer and shall essentially duplicate equipment which has been in satisfactory service for at least one (1) year.
- B. First of a kind new technology devices will not be considered.
- C. Accessory equipment that is required to make a complete and functioning system that is not of the same manufacturer furnishing the basic materials or equipment shall carry the guarantee of the basic material or equipment manufacturer and repair and replacement parts shall be available through normal trade channels locally.

1.21 CLEAN UP

- A. Contractor shall be responsible for cleaning up after and during all work performed under this Division of the Specifications.

- B. Contractor shall, on a daily basis, remove construction trash and debris accumulation to minimize the entrance of dust, dirt, and debris in piping, ductwork, and mechanical equipment.
- C. At the completion of construction, just prior to Substantial Completion and sustained operation of equipment, thoroughly clean the inside of piping, ductwork, and equipment.
- D. Refer to Division 1.

1.22 FINAL CONSTRUCTION REVIEW

- A. Schedule: Upon completion of the work specified in Division 23, there shall be a final construction review of the completed mechanical systems installations. Prior to this walk-thru, all work specified in this Division shall have been completed, tested, adjusted, and balanced in its final operating condition and the preliminary test report shall have been submitted to and approved by the Engineer.
- B. Personnel: A qualified person representing the Contractor must be present at this final construction review to demonstrate the system and prove the performance of the equipment.
- C. Building mechanical systems shall have been in operation for a minimum of 15 days and Test and Balance work shall be substantially complete prior to this review.
- D. Exceptions to the aforementioned requirements will be considered on a case-by-case basis dependent on the size and type of project, as well as construction schedule limitations.

1.23 CERTIFICATIONS

- A. Before receiving final payment, the Contractor shall certify that all equipment furnished and all work done is in compliance with all applicable codes mentioned in these Specifications.
- B. Provide copies of all applicable approved notices and inspection certifications from the various inspections conducted by the Local Code Enforcement Authorities.

1.24 GUARANTEE

- A. The guarantee provision of this specification requires prompt replacement of all defective workmanship and materials occurring within one year of final job acceptance, Substantial Completion, or as defined by Extended Warranty Contracts. This includes all work required to remove and replace the defective item and to make all necessary

adjustments to restore the entire installation to its original specified operating condition and finish at the time of acceptance.

- B. The Contractor shall also guarantee that the performance of all equipment furnished and installed under this Division of the Specifications shall be at least equal to the performance as called for in the specifications and as stated in the equipment submittals. Should there be indication that the equipment and installation is not producing the intended conditions, the Contractor shall make further tests as the Owner's Representative may direct to demonstrate that the equipment installed meets the specifications and is delivering the capacity specified or called for on the Drawings.
- C. If there is any indication that the equipment does not meet the specified quantities, the Contractor shall, at his expense, institute a program to demonstrate the adequacy of the installation. This program shall include all necessary testing and testing equipment. Should the Contractor not have the equipment or technical skill to perform the tests, it shall be his responsibility to employ recognized experts to perform the tests and shall provide certified laboratory tests, certified factory reports and work sheets, or other certified data to support results of any tests required.

END OF SECTION