

Midlothian Independent School District Request for Proposal RFP# 2021-022

Monitoring of Fire Alarm Systems, Inspection, Service & Repair Addendum 2 (issued May 13, 2021)

Clarification of Scope of work:

 Fire alarm signals will be monitored by telephone line, 4G/LTE, network communications and/or long-range radio signals or as designated by District-approved means of transmission.

Response:

The preferred method of Fire Alarm monitoring is by cellular radio signal.